

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 892

Dated: 16/5/25

It is certified that an inspection team headed by Haramanpreet Singh (SPE)
 (Name of Officers with designation) from Water Supply & Sanitation Department
 (Name of Department/ Office) inspected the SUNFIELD INTERNATIONAL SCHOOL DULCHINTRA ROPAR
 (Name & Address of the school) on 16/5/2025 (date of inspection) and found that
 the P.W.T. LRPR/2526/00036 (Name of school) has safe drinking water facilities
 for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
 The above is valid for a period of 2 years.

Signature with Seal:

Haramanpreet Singh
 Sub Divisional Engineer :
 Water Supply & Sanitation :
 Sub Division Designation :

Name & Address of the Office / Department :

To
SUNFIELD INTERNATIONAL SCHOOL
DULCHINTRA SALAPUR CHOWK - ROPAR
 (Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

DISTRICT WATER TESTING LABORATORY, ROOPNAGAR

Department of Water Supply and Sanitation, Division -2, Roopnagar

dwtlrpr@gmail.com

TEST REPORT


Name & Address of Customer : Sunfields International School, Dulchi Majra, Roopnagar Sunfields International School, Dulchi Majra, Roopnagar		Customer Reference No.	No : Letter No. SIS/2025 Dated : 06/05/2025
		Sample Submitted by	
		Date of Sample Receipt	07/05/2025
		Analysis Starting Date	12/05/2025
Discipline : Chemical Testing		Group: Water	
JLR No.:	TC98822500000164F	Sample Type :	Water
Test Report No.:	DWTLRPR/2526/00036	Date of Issue :	16/05/2025
Registration no.:	DWTLRPR/REG2526/00115	Condition of Sample :	Unsealed
Collection Point:	Distribution Point(Near Bus stand, School, Gurudwara, etc)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Sunfields International School, Dulchi Majra, Roopnagar (TAP WATER) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Roopnagar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.46@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Meth
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
5	TDS	318	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.25	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Metho
7	Alkalinity(CaCO3)	168	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	208	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Metho
9	Calcium(Ca)	24.05	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Metho
10	Magnesium(Mg)	35.96	30	100	mg/l	APHA (24th Ed.2023) Method. 3500-Mg+2 B B Calculation Method
11	Chloride(Cl)	12	250	1000	mg/l	IS 3025 (Part 32-198S) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By



Mr. Praveen Singh Danu
Chemist/Analyst
Authorized Signatory
For, District Water Testing Laboratory
Roopnagar

----- End of the Test Report -----